
AIR DISTRIBUTION SUBMITTAL

FRAME-IN APPLICATION (FM)

(SHOWN WITH SNAP-ON PLENUM)


SURFACE MOUNT APPLICATION (SM)

(SHOWN WITH HEMMED-EDGE PLENUM)



PLASTER-IN APPLICATION (22)

(SHOWN WITH SNAP-ON PLENUM)



FRAME TYPE 22 IS NOT AVAILABLE FOR ALL SLOT CONFIGURATIONS. CONTACT FACTORY.


| | SLOT WIDTH S | OVERALL WIDTH O.A. | DUCT WIDTH D | w | Н |
|-----------|-----------------|-----------------------|-----------------|----------------|----------------|
| WF2000-10 | 1 | 3 3 | 3 1 | 2 5 | 2 1 |
| WF2000-15 | 1 ½ | 4 1 | 3 3 | 3 1 | 2 1 |
| WF2000-20 | 2 | 4 3/4 | 4 1/4 | 3 5 | 2 1 |
| WF2000-25 | $2\frac{1}{2}$ | 6 5 | 6 | 5 ½ | 3 |
| WF2000-30 | 3 | 7 1 | 6 1/2 | 6 | 3 |

SUPPLY

□ WF2000ST-10 1" SLOT

□ WF2000ST-15 1 1/2" SLOT □ WF2000ST-20 2" SLOT

☐ WF2000ST-25 2 1/2" SLOT ☐ WF2000ST-30 3" SLOT




RETURN


□ WF2000R-10 1" SLOT


□ WF2000R-15 1 1/2" SLOT □ WF2000R-20 2" SLOT


☐ WF2000R-25 2 1/2" SLOT ☐ WF2000R-30 3" SLOT



END VARIATION







OVERALL LENGTH (O)

LENGTH DIMENSIONS

| OPEN-OPEN (OO) | FLANGE-OPEN (FO) | FLANGE-FLANGE (FF) | | |
|----------------|-----------------------|------------------------|--|--|
| D = L | $D = L + \frac{1}{8}$ | $D = L + \frac{1}{4}$ | | |
| 0 = L | $0 = L+1\frac{1}{8}$ | $0 = L + 2\frac{1}{4}$ | | |

FEATURES

- · FACE CONSTRUCTION OF HEAVY WALL ALUMINUM WITH WHITE FINISH • PATTERN CONTROL AND FRAME MEMBERS CONSTRUCTED OF 24 GA. STEEL WITH BLACK FINISH.
- PATTERN CONTROL PROVIDES 180 DEGREES THROW ADJUSTMENT
- PATTERN CONTROL FURNISHED IN MULTIPLE SECTIONS FOR DIFFUSERS LONGER THAN 3FT.
- · SECTIONS UP TO 8 FT. CAN BE PROVIDED
- · CURVED SECTIONS AVAILABLE. CONTACT FACTORY
- · BLANK OFF PANELS AVAILABLE. CONTACT FACTORY
- · LIGHT SHIELDS AVAILABLE. CONTACT FACTORY

OPTIONS (SPECIFY)

- __ LINEAR LENGTH (L)
- END VARIATION (OO) (FO) (FF)
- SURFACE MOUNT (SM)
- ☐ FRAME-IN MOUNT (FM)
- ☐ PLASTER-IN MOUNT (22)

STANDARD INDUSTRY TOLERANCES APPLY. SPECIFICATIONS ARE SUBJECT TO CHANGE WITHOUT NOTICE.

JOB NAME: LOCATION: _ ARCHITECT: _ ENGINEER: _

DRAWN BY JLH

DATE 9-10-02

WF2000 ST ONE SLOT

STANDARD THROW

WIDE FLOW LINEAR DIFFUSER

DWG. NO. WF2000ST-1B

P.O. BOX 250 ALBION, IOWA 50005 PH. (641) 488-2211 FAX (641) 488-2796 www.raymon-hvac.com

CONTRACTOR:

